



Product Service

# Attestation of Conformity

No. N8A 086470 0242 Rev. 00

**Holder of Attestation:** **Ginlong Technologies Co., Ltd.**No.57 Jintong Road  
Binhai Industrial Park, Xiangshan  
315712 Ningbo, Zhejiang  
PEOPLE'S REPUBLIC OF CHINA**Product:** **PV inverter****Grid-connected PV Inverter****Model(s):**S6-GC3P20K04-NV-ND-R, S6-GC3P23K03-LV-ND,  
S6-GC3P25K04-LV-ND, S6-GC3P25K04-NV-ND-R,  
S6-GC3P27.6K04-NV-ND-R, S6-GC3P30K04-LV-ND,  
S6-GC3P30K04-NV-ND-R, S6-GC3P33K04-NV-ND-R,  
S6-GC3P36K04-LV-ND, S6-GC3P36K04-NV-ND-R,  
S6-GC3P37.5K04-LV-ND, S6-GC3P37.5K04-NV-ND,  
S6-GC3P40K04-NV-ND, S6-GC3P40K04-NV-ND-R,  
S6-GC3P50K04-HV-ND, S6-GC3P50K04-NV-ND,  
S6-GC3P60K05-HV-ND, S6-GC3P60K05-NV-ND**Parameters:** See next pages**Tested according to:** EN 62109-1:2010  
EN 62109-2:2011

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 5040924001353-00**Date,** 2025-01-21

( Zhengdong Ma )

Page 1 of 7

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

# Attestation of Conformity

No. N8A 086470 0242 Rev. 00

Model	S6-GC3P20K04-NV-ND-R	S6-GC3P25K04-NV-ND-R	S6-GC3P27.6K04-NV-ND-R
Parameter			
<b>PV input</b>			
Max. input voltage	1100 Vd.c.		
MPPT voltage range	180, ..., 1000Vd.c.		
Max. input current	4 x 40 Ad.c.		
Isc PV (absolute maximum)	4 x 50 Ad.c.		
<b>AC output (Grid)</b>			
Nominal grid voltage	3/N/PE 220/380 Va.c., or 3/N/PE 230/400 Va.c.	3/N/PE 220/380 Va.c., or 3/N/PE 230/400 Va.c.	3/N/PE 230/400 Va.c.
Nominal grid frequency	50 / 60 Hz		
Nominal output power	20000 W	25000 W	27600 W
Max.(rated) AC output active power	20000 W	25000 W	27600 W
Max.(rated) AC output apparent power	20000 VA	25000 VA	27600 VA
Max.(rated) output current	30.3Aa.c.@ 220/380Va.c. 29.0Aa.c.@ 230/400Va.c.	38.0Aa.c.@ 220/380Va.c. 36.1Aa.c.@ 230/400Va.c.	40.0Aa.c.
Power factor range	-0.8, ..., 1, ..., +0.8		
<b>General</b>			
Protective class	I		
Ingress protection	IP 66		
Operating temperature Range	-25 °C, ..., +60 °C		
Overvoltage category	II(PV), III(MAINS)		
Topology	Non-isolated		

Page 2 of 7

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

# Attestation of Conformity

No. N8A 086470 0242 Rev. 00

Model	S6-GC3P30K04-NV-ND-R	S6-GC3P33K04-NV-ND-R	S6-GC3P36K04-NV-ND-R
Parameter			
<b>PV input</b>			
Max. input voltage	1100 Vd.c.		
MPPT voltage range	180, ..., 1000Vd.c.		
Max. input current	4 x 40 Ad.c.		
Isc PV (absolute maximum)	4 x 50 Ad.c.		
<b>AC output (Grid)</b>			
Nominal grid voltage	3/N/PE 220/380 Va.c., or 3/N/PE 230/400 Va.c.	3/N/PE 220/380 Va.c., or 3/N/PE 230/400 Va.c.	3/N/PE 220/380 Va.c., or 3/N/PE 230/400 Va.c.
Nominal grid frequency	50 / 60 Hz		
Nominal output power	30000 W	33000 W	36000 W
Max.(rated) AC output active power	30000 W	33000 W	36000 W
Max.(rated) AC output apparent power	30000 VA	33000 VA	36000 VA
Max.(rated) output current	45.5Aa.c.@ 220/380Va.c. 43.5Aa.c.@ 230/400Va.c.	50.1Aa.c.@ 220/380Va.c. 47.6Aa.c.@ 230/400Va.c.	54.7Aa.c.@ 220/380Va.c. 52.0Aa.c.@ 230/400Va.c.
Power factor range	-0.8, ..., 1, ..., +0.8		
<b>General</b>			
Protective class	I		
Ingress protection	IP 66		
Operating temperature Range	-25 °C, ..., +60 °C		
Overvoltage category	II(PV), III(MAINS)		
Topology	Non-isolated		

Page 3 of 7

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

# Attestation of Conformity

No. N8A 086470 0242 Rev. 00

Model	S6-GC3P37.5K04-NV-ND	S6-GC3P40K04-NV-ND	S6-GC3P40K04-NV-ND-R
Parameter			
<b>PV input</b>			
Max. input voltage	1100 Vd.c.		
MPPT voltage range	180, ..., 1000Vd.c.		
Max. input current	4 x 40 Ad.c.		
Isc PV (absolute maximum)	4 x 50 Ad.c.		
<b>AC output (Grid)</b>			
Nominal grid voltage	3/N/PE 220/380 Va.c.	3/N/PE 220/380 Va.c., or 3/N/PE 230/400 Va.c.	3/N/PE 220/380 Va.c., or 3/N/PE 230/400 Va.c.
Nominal grid frequency	50 / 60 Hz		
Nominal output power	37500W	40000W	40000W
Max.(rated) AC output active power	37500W	40000W	40000W
Max.(rated) AC output apparent power	37500VA	40000VA	40000VA
Max.(rated) output current	57.0Aa.c.	60.8Aa.c.@ 220/380Va.c. 57.7Aa.c.@ 230/400Va.c.	60.8Aa.c.@ 220/380Va.c. 57.7Aa.c.@ 230/400Va.c.
Power factor range	-0.8, ..., 1, ..., +0.8		
<b>General</b>			
Protective class	I		
Ingress protection	IP 66		
Operating temperature Range	-25 °C, ..., +60 °C		
Overvoltage category	II(PV), III(MAINS)		
Topology	Non-isolated		

Page 4 of 7

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

# Attestation of Conformity

No. N8A 086470 0242 Rev. 00

Model	S6-GC3P50K04-NV-ND	S6-GC3P60K05-NV-ND	S6-GC3P37.5K04-LV-ND
Parameter			
<b>PV input</b>			
Max. input voltage	1100 Vd.c.		
MPPT voltage range	180, ..., 1000Vd.c.		
Max. input current	4 x 40 Ad.c.	5 x 40 Ad.c.	4 x 40 Ad.c.
Isc PV (absolute maximum)	4 x 50 Ad.c.	5 x 50 Ad.c.	4 x 50 Ad.c.
<b>AC output (Grid)</b>			
Nominal grid voltage	3/N/PE 220/380 Va.c., or 3/N/PE 230/400 Va.c.	3/N/PE 220/380 Va.c., or 3/N/PE 230/400 Va.c.	3/PE 220 Va.c.
Nominal grid frequency	50 / 60 Hz		
Nominal output power	50000 W	60000 W	37500 W
Max.(rated) AC output active power	50000 W	60000 W	37500 W
Max.(rated) AC output apparent power	50000 VA	60000 VA	37500 VA
Max.(rated) output current	76.0Aa.c.@ 220/380Va.c. 72.2Aa.c.@ 230/400Va.c.	91.2Aa.c.@ 220/380Va.c. 86.6Aa.c.@ 230/400Va.c.	98.4Aa.c.
Power factor range	-0.8, ..., 1, ..., +0.8		
<b>General</b>			
Protective class	I		
Ingress protection	IP 66		
Operating temperature Range	-25 °C, ..., +60 °C		
Overvoltage category	II(PV), III(MAINS)		
Topology	Non-isolated		

Page 5 of 7

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



# Attestation of Conformity

No. N8A 086470 0242 Rev. 00

Model	S6-GC3P23K03-LV-ND	S6-GC3P25K04-LV-ND	S6-GC3P30K04-LV-ND
Parameter			
<b>PV input</b>			
Max. input voltage	1100 Vd.c.		
MPPT voltage range	180, ..., 1000Vd.c.		
Max. input current	3 x 40 Ad.c.	4 x 40 Ad.c.	4 x 40 Ad.c.
Isc PV (absolute maximum)	3 x 50 Ad.c.	4 x 50 Ad.c.	4 x 50 Ad.c.
<b>AC output (Grid)</b>			
Nominal grid voltage	3/PE 220Va.c. or 3/PE 230Va.c.	3/PE 220Va.c. or 3/PE 230Va.c.	3/PE 220Va.c. or 3/PE 230Va.c.
Nominal grid frequency	50 / 60 Hz		
Nominal output power	23000W	25000W	30000W
Max.(rated) AC output active power	23000W	25000W	30000W
Max.(rated) AC output apparent power	23000VA	25000VA	30000VA
Max.(rated) output current	60.4Aa.c.@ 220Va.c., 57.7Aa.c.@ 230Va.c.	65.6Aa.c.@ 220Va.c., 62.8Aa.c.@ 230Va.c.	78.7Aa.c.@ 220Va.c., 75.3Aa.c.@ 230Va.c.
Power factor range	-0.8, ..., 1, ..., +0.8		
<b>General</b>			
Protective class	I		
Ingress protection	IP 66		
Operating temperature Range	-25 °C, ..., +60 °C		
Overvoltage category	II(PV), III(MAINS)		
Topology	Non-isolated		

Page 6 of 7

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

# Attestation of Conformity

No. N8A 086470 0242 Rev. 00

Model	S6-GC3P36K04-LV-ND	S6-GC3P50K04-HV-ND	S6-GC3P60K05-HV-ND
Parameter			
<b>PV input</b>			
Max. input voltage	1100 Vd.c.		
MPPT voltage range	180, ..., 1000Vd.c.		
Max. input current	4 x 40 Ad.c.	4 x 40 Ad.c.	5 x 40 Ad.c.
Isc PV (absolute maximum)	4 x 50 Ad.c.	4 x 50 Ad.c.	5 x 50 Ad.c.
<b>AC output (Grid)</b>			
Nominal grid voltage	3/PE 220Va.c. or 3/PE 230Va.c.	3/PE 480Va.c.	3/PE 480Va.c.
Nominal grid frequency	50 / 60 Hz		
Nominal output power	36000 W	50000 W	60000 W
Max.(rated) AC output active power	36000 W	50000 W	60000 W
Max.(rated) AC output apparent power	36000 VA	50000 VA	60000 VA
Max.(rated) output current	94.5Aa.c.@ 220Va.c., 90.4Aa.c.@ 230Va.c.	60.1Aa.c.	72.2Aa.c.
Power factor range	-0.8, ..., 1, ..., +0.8		
<b>General</b>			
Protective class	I		
Ingress protection	IP 66		
Operating temperature Range	-25 °C, ..., +60 °C		
Overvoltage category	II(PV), III(MAINS)		
Topology	Non-isolated		

Page 7 of 7

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.